

Certificate of Constancy of Performance 2812-CPR-AD0267

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

CISA D7200.04.0 & D7210.04.0 Overhead Door Closers

Intended use: For use on fire rated single leaf and double leaf doors STANDARD DOOR MOUNT AND TRANSOM MOUNT PULL SIDE APPLICATION

Essential characteristics	Performance	Harmonised Technical	
		Specification	
Mechanical Test Evidence: 1849	49A lss 2 / 184949B / 186956A lss 2 / 1869	56B lss 2 / 188841 / 188842A &	
188842B			
Fire Test Evidence: WF 187201 & WF 188311 lss 2			
Self-closing			
5.2.1 General			
5.2.2 Durability	500,000 test cycles		
5.2.3 Closing moment	Pass size 2 to 5		
5.2.4 Opening moment	Pass size 2 to 5		
5.2.5 Efficiency	> 50% size 2		
5.2.5 Efficiency	> 65% size 5		
5.2.6 Closing time	Pass		
5.2.7 Angles of operation	Grade 4 180°	EN1154:1996/A1:2002/AC:2006	
5.2.8 Overload performance	Pass		
5.2.9 Temp dependence	-15°C to +40°C		
5.2.10 Fluid leakage	Pass		
5.2.11 Damage	Pass		
5.2.12 Latch control	Pass		
5.2.13 Back check (optional)	Pass		
5.2.14 Delayed closing (optional)	Pass		
5.2.15 Adjustable closing force	Pass		
(optional)			
5.2.16 Zero position (double action	NPD		
door closers only)			
5.2.18 Fire/smoke door suitability	Pass		
Essential characteristics	Performance	Harmonised Technical	
		Specification	
Durability of Self Closing			
5.2.2 Durability	500,000 test cycles		
5.2.17.1 Corrosion	Grade 3 (96 hours)		
5.2.17.2 Corrosion	Pass		
Dangerous Substances	Pass: the materials in the door closer do	EN1154:1996/A1:2002/AC:2006	
Annex ZA3	not contain or release any dangerous		
	substances in excess of the maximum		
	levels specified in existing European		
	material standards or any national		
	regulations		





Certificate of Constancy of Performance 2812-CPR-AD0267

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

D7210.04.0 Overhead Door Closer

Intended use: For use on fire rated single leaf and double leaf doors DOOR MOUNT PUSH SIDE APPLICATION

DOOR MOUNT PUSH SIDE APPLICATION Essential characteristics	Performance	Harmonised Technical
Loociitiai ciiai acteriotico	CHOIMANGE	Specification
Self-closing		
5.2.1 General		
5.2.2 Durability	500,000 test cycles	
5.2.3 Closing moment	Pass size 2 to 5	
5.2.4 Opening moment	Pass size 2 to 5	
5.2.5 Efficiency	> 50% size 2	
5.2.5 Efficiency	> 65% size 5	
5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 3, >105°	EN1154:1996/A1:2002/AC:2006
5.2.8 Overload performance	Pass	
5.2.9 Temp dependence	-15°C to +40°C	
5.2.10 Fluid leakage	Pass	
5.2.11 Damage	Pass	
5.2.12 Latch control	Pass	
5.2.13 Back check (optional)	Pass	
5.2.14 Delayed closing (optional)	Pass	
5.2.15 Adjustable closing force	Pass	
(optional)		
5.2.16 Zero position (double action	NPD	
door closers only)		
5.2.18 Fire/smoke door suitability	Pass	
Essential characteristics	Performance	Harmonised Technical Specification
Durability of Self Closing		
5.2.2 Durability	500,000 test cycles	
5.2.17.1 Corrosion	Grade 3 (96 hours)	
5.2.17.2 Corrosion	Pass	
Dangerous Substances	Pass: the materials in the door closer do	EN1154:1996/A1:2002/AC:2006
Annex ZA3	not contain or release any dangerous	
	substances in excess of the maximum	
	levels specified in existing European	
	material standards or any national	
	regulations	



Certificate of Constancy of Performance 2812-CPR-AD0267

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

D7200.04.0 Overhead Door Closer

Intended use: For use on fire rated single leaf and double leaf doors

TRANSOM MOUNT PUSH SIDE APP Essential characteristics	Performance	Harmonised Technical
Lascritiai criaracteristics	1 chomiane	Specification
Self-closing		•
5.2.1 General		
5.2.2 Durability	500,000 test cycles	
5.2.3 Closing moment	Pass size 2 to 4	
5.2.4 Opening moment	Pass size 2 to 4	
5.2.5 Efficiency	> 50% size 2	
5.2.5 Efficiency	> 60% size 4	
5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 3, >105°	EN1154:1996/A1:2002/AC:2006
5.2.8 Overload performance	Pass	
5.2.9 Temp dependence	-15°C to +40°C	
5.2.10 Fluid leakage	Pass	
5.2.11 Damage	Pass	
5.2.12 Latch control	Pass	
5.2.13 Back check (optional)	Pass	
5.2.14 Delayed closing (optional)	NPD	
5.2.15 Adjustable closing force	Pass	
(optional)		
5.2.16 Zero position (double action	NPD	
door closers only)		
5.2.18 Fire/smoke door suitability	Pass	
Essential characteristics	Performance	Harmonised Technical
		Specification
Durability of Self Closing		
5.2.2 Durability	500,000 test cycles	
5.2.17.1 Corrosion	Grade 3 (96 hours)	
5.2.17.2 Corrosion	Pass	
Dangerous Substances	Pass: the materials in the door closer do	EN1154:1996/A1:2002/AC:2006
Annex ZA3	not contain or release any dangerous	
	substances in excess of the maximum	
	levels specified in existing European	
	material standards or any national	
	regulations	



Certificate of Constancy of Performance 2812-CPR-AD0267

Placed on the market under the name or trade mark of

Allegion CISA S.p.A Via Oberdan 42 Faenza (RA) 48018 Italy

and produced in the manufacturing plant

K//067

This is coded format and the information is held by the Notified Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard:

EN 1154:1996 / A1:2002 / AC:2006

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **05/11/2020** and re-issued on **28/06/2023** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: 27/06/2026

ERO Project Reference: ERO 034621 P1910

Pascal Coget General Manager -European Certification

CSF408-NL 7.0

