

DICHIARAZIONE DI PRESTAZIONE DECLARATION OF PERFORMANCE

Ai sensi del REGOLAMENTO (UE) N. 305/2011

n. 34-1125-2013 rev.1

1. Codice di identificazione unico del prodotto-tipo:

Unique identification code of the product-type:

Dispositivi antipanico per uscite di sicurezza azionati mediante barra orizzontale Serie
“Fast Push”

Panic exit devices: “Fast Push”

2. Numero di tipo ai sensi dell'articolo 11, paragrafo 4:

Type number as required pursuant to Article 11(4):

Series “FAST PUSH” 1.59001.10.0.xx.xx.FR, 1.59011.10.0.xx.xx.FR,
1.59016.10.0.xx.FR

Bars 1.07007.13/60.0.xx, 1.07007.14/61.0.xx, 1.07007.15/62.0.xx

Locking points 1.07063.51.0.xx.xx.FR, 1.07063.61.0.xx.xx.FR,
1.07063.66.1/2.xx.xx.FR, 1.07063.71.0.xx.xx, 1.07063.26.1/2.xx.xx.FR

Strikers 1.07072.2x.0.xx, 1.07072.7x.0.xx

Handles 1.07077.4x.0.xx, 1.07074.80.0.xx

3. Uso o usi previsti del prodotto da costruzione, conformemente alla relativa specifica tecnica armonizzata, come previsto dal fabbricante:

Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

Dispositivi antipanico per uscite di sicurezza da utilizzare su porte sulla via dell'esodo e anche resistenti al fuoco e/o al fumo

Exit panic devices to be used for locked doors on escape routes and on fire/smoke doors

4. Nome, denominazione commerciale registrata o marchio registrato e indirizzo del fabbricante ai sensi dell'articolo 11, paragrafo 5:

Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

9. Prestazione dichiarata *Declared Performance*

Essential Characteristic	Performance	Harmonised technical specification
Ability to release (for locked doors on escape routes)		
Release function	≤ 1 s	EN1125:2008 par. 4.1.2
Panic exit device mounting	Pass	EN1125:2008 par. 4.1.3
Exposed edges and corners	$\geq 0,5$ mm	EN1125:2008 par. 4.1.5
Double doorset	Pass	EN1125:2008 par. 4.1.7
Bar installation	$Z \leq 150$ mm	EN1125:2008 par. 4.1.9
Bar length	≥ 60 % of the door width	EN1125:2008 par. 4.1.10
Bar projection	$W = 94$ mm	EN1125:2008 par. 4.1.11
Bar end	Pass	EN1125:2008 par. 4.1.12
Operating bar face	$V = 30$ mm	EN1125:2008 par. 4.1.13
Test rod	Pass	EN1125:2008 par. 4.1.14
Door face gap	$R = > 25$ mm	EN1125:2008 par. 4.1.15
Accessible gap	Pass	EN1125:2008 par. 4.1.16
Door free movement	Pass	EN1125:2008 par. 4.1.17
Top vertical bolt	Pass	EN1125:2008 par. 4.1.18
Keepers	Pass	EN1125:2008 par. 4.1.20
Keepers dimensions	$H \leq 15$ mm $M \leq 45^\circ$ $P \leq 3$ mm	EN1125:2008 par. 4.1.21
Door mass and dimensions	Grade 7	EN1125:2008 par.4.1.23 6.3.2 6.3.4 6.3.5 6.3.6 6.3.8
Outside access device	Pass	EN1125:2008 par. 4.1.24 6.3.2
Release forces	≤ 80 N e/and ≤ 220 Nunder pressure	EN1125:2008 par.4.2.2 6.3.2
Security requirement	Grade 2	EN1125:2008 par. 6.3.7
Durability of ability to release(for locked doors on escape routes)		
Corrosion resistance	Grade 4; 240h salt spray fog	EN1125:2008 par. 6.2.3
Temperature range	(-10°C / $+60^\circ\text{C}$) 50 % in excess	EN1125:2008 par. 6.2.2
Covers for vertical rods	500 N	EN1125:2008 par. 4.1.19 6.3.6
Lubrication	20 000 cycles	EN1125:2008 par. 4.1.22 6.3.4
Re-engagement force	≤ 50 N	EN1125:2008 par. 4.2.3 6.3.3
Durability	Grade 7; 200000cycles	EN1125:2008 par.4.2.4 6.3.4

Abuse resistance – Horizontal bar	1000 N	EN1125:2008 par. 4.2.5 6.3.5
Abuse resistance – Vertical rod	500 N	EN1125:2008 par. 6.3.6 or 4.1.19 4.2.6
Self closing ability C against aging and degradation (for fire/smoke doors on escape routes)		
Re-engagement force	Threshold (<= 50 N)	EN1125:2008 par. 6.3.3
Durability of Self closing ability C against aging and degradation (for fire/smoke doors on escape routes)		
Durability	Grade 7, 200000cycles	EN1125:2008 par. 6.3.4
Re-engagement force	Threshold (<= 50 N)	EN1125:2008 par. 6.3.3
Resistance to fire E (integrity) and I(insulation)(for use on fire doors)		
Suitability of panic exit devices for use on fire resisting doorsets assemblies - - Additional requirements	Suitable for use on fire door assemblies	EN1125:2008 Annex B
Dangerous substances		
Control of dangerous substances	Pass	EN1125:2008 par. 4.1.25

10. La prestazione del prodotto di cui ai punti 1 e 2 è conforme alla prestazione dichiarata di cui al punto 9.

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

Si rilascia la presente dichiarazione di prestazione sotto la responsabilità esclusiva del fabbricante di cui al punto 4.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Firmato a nome e per conto del costruttore:
Signed for and on behalf of the manufacturer by:

Il Legale Rappresentante
Legal Representative

Faenza (RA) 18/11/2020.....
(luogo e data del rilascio)
(place and date of issue)

CISA S.p.A.
Via G. Oberdan, 42
FAENZA.....
(firma)
(signature)